

# MIAMI-DADE FIRE RESCUE DEPARTMENT - INSPECTION REPORT



FIRE PREVENTION DIVISION  
 9300 NW 41 STREET, MIAMI, FLORIDA 33178  
 PHONE 786.331.4800 FAX 786.331.4801



**PERMIT #** 08121-00012

**Permit Type:** Education Inspection **Month:** February  
**Billing Address:**  
 DCPS COPE CENTER NORTH  
 9950 NW 19TH AVE STE B MIAMI, FL 33147

**Inspection Date:** 02/20/2014  
**Inspector:** PATRICK GAINES  
**Inspector phone:** (786) 336-6842

**RESULT: Referred to State**

**DCPS COPE CENTER NORTH**  
**9950 NW 19 AVE**  
**MIAMI, FL 33147**

### NOTICE OF VIOLATIONS AND ORDER TO CORRECT

The hazards noted are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code. Nothing in this report supersedes any previously written, still existing violations for this occupancy. You are ordered to comply with the corrective measures within the time prescribed.

**Please Note:** A life safety permit required by County Code# 14-53 to operate within Miami-Dade County will be issued upon correction of all outstanding violations and payment of fees assessed. Failure to obtain the required Life Safety Permit will result in Enforcement Actions including fines, citations, liens and/or orders to cease and desist operation.

### APPEALS

Any person that believes they were incorrectly issued a violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami-Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 15 days** of receiving the *Notice of Violation and Order to Correct*. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp> or by calling 786-331-4820. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal.  
 Code of Miami-Dade County, Part III, Chapter 14, Section 14-48

Viol.	Inspection Date	Comply by Date	VIOLATION, CORRECTION & COMMENTS
1	2/20/14	2/23/13	<p><b>Violation:</b> Code of Miami-Dade County 14-53(F) All applications for permits pursuant to this section shall be on a form prescribed by the Fire Department having jurisdiction and accompanied by the required fee. The fees shall be established by administrative order of the County Manager and approved by the Board of County Commissioners for permits within the jurisdiction of the Metropolitan Dade County Fire Department. The fees shall be established by the governing body of the City of Miami Beach, the City of Miami, the City of Hialeah and the City of Coral Gables for such permits within the respective jurisdictions of the aforesaid municipalities.</p> <p><b>Correction:</b> Call 786-331-4800. Request the total amount of fees owed for the Life Safety Permit. Arrange payment of all fees owed.</p> <p><b>Comments:</b> PAY OUTSTANDING FEES.</p>
2	2/20/14	2/20/14	<p><b>Violation:</b> NFPA 1 13.1.7 All fire protection systems and devices shall be maintained in a reliable operating condition and shall be replaced or repaired where defective or recalled.</p> <p><b>Correction:</b> Maintain all fire protection systems and devices in reliable operating condition and replace or repair where defective.</p> <p><b>Comments:</b> 2013 FIRE SPRINKLER INSPECTION REPORTS INDICATE DEFICIENCIES - HAVE SPRINKLER CONTRACTOR MAKE ALL NECESSARY REPAIRS TO SYSTEM.</p>

Violation Corrected

### CUSTOMER SIGN OFF

Title: Agency  
 Name: